



दिल्ली छावनी परिषद

**DELHI CANTONMENT BOARD**  
सदरबाजार, दिल्ली छावनी- 110010  
Sadar Bazar, Delhi Cantt - 110010  
हर काम देश के नाम



Tel. No.: 011-25693837, 25695450 ✉: [ceodelhicantt@gmail.com](mailto:ceodelhicantt@gmail.com), 🌐: [www.delhi.cantt.gov.in](http://www.delhi.cantt.gov.in)

No. DCB/32/SN-1/ Misc /2023-24

Dated: 17 May, 2023

**TO WHOMSOEVER IT MAY CONCERN**

It is certified that the sanitary conditions of Mount St. Mary's school, 75, Parade Road, Delhi Cantt -10 has found satisfactory.

*Gyanendra*

**(Gyanendra Pal Singh)**  
OIC Sanitation  
Delhi Cantonment Board

To

The Principal  
Mount St. Mary's School  
Delhi Cantt



visit us [www.delllabs.in](http://www.delllabs.in)

CIN : U93000DL2012PTC230051

## TEST REPORT

### Water Sample Analysis

Test Certificate No.	DEMCC/22/01WS	Ref Date	Nil
Issue Date	15/12/2022	Date of Collection	10/12/2022
Issued To	The Principal Mount St Marry's School Delhi Cantt	Sample Collected By	DEMCCPL
Sample Collected From	Clear Water Sample	Protocol Used For Sample Collection Page	IS 3025 & IS 1622 1 of 1

## RESULTS

Protocol Used	IS 3025, APHA & IS 1622
Cross Ref. No.	IS 10500-2012 10/12/2022 to 15/12/2022

Sl. No.	Parameter	Results	Permissible Limits <small>(In the absence of alternate source)</small>
1.	Colour, Hazen	Colourless	5 (15) Max
2.	Odour	Un objectionable	Un objectionable
3.	Taste	Agreeable	Agreeable
4.	Turbidity, NTU	< 1	1(10) Max
5.	PH	7.27	6.5-8.5
6.	Total Hardness as Caco3, Mg/l	51	200(600) Max
7.	Chloride as Cl, Mg/l	12	250(1000) Max
8.	Total Iron as Fe, Mg/l	0.02	0.3 Max
9.	Total Dissolved Solids, Mg/l	143	500(2000)Max
10.	RFC, Mg/l	Nil	0.2 (1) Max
11.	Sulphates as So4, Mg/l	11.2	200(400) Max
12.	Nitrates as No3, Mg/l	4.1	45(100) Max
13.	Fluorides as F, Mg/l	1.03	1.0(1.5) Max
14.	Lead as Pb, Mg/l	BDL	0.05 Max
15.	Copper as Cu,Mg/l	BDL	0.05(1.5) Max
16.	Manganese as Mn,Mg/l	BDL	0.1(0.3) Max
17.	Phenolic Compound as C6H5OH,Mg/l	BDL	0.001(0.002) Max
18.	Mercury as Hg,Mg/l	BDL	0.001 Max
19.	Cadmium as Cd,Mg/l	BDL	0.01 Max
20.	Selenium as Se, Mg/l	BDL	0.01 Max
21.	Arsenic as As,Mg/l	BDL	0.05 Max
22.	Cyanide as Cn,Mg/l	BDL	0.05 Max
23.	Zinc as Zn, Mg/l	ND	5(15) Max
24.	Detergent as MBAS, Mg/l	BDL	0.2(1.0) Max
25.	Chromium as Cr+6 ,Mg/l	BDL	0.05 Max
26.	Total Alkalinity as Caco3,Mg/l	109	200 Max
27.	Aluminum as Al,Mg/l	BDL	0.03 (0.2) Max
28.	Boron as B, Mg/l	BDL	1 Max
29.	Barium as Ba,Mg/l	BDL	0.7 Max
30.	Chloramines as Cl2,Mg/l	BDL	4.0 Max
31.	Mineral Oil,Mg/l	BDL	0.5 Max
32.	<b>Bacteriological Analysis</b>		
	Coliform,MPN/100MI	Nil	Negative
	E-coli/100MI	Negative	Negative

Note: BDL: Below Detection Limit

Remark: Terms & Conditions Mentioned Overleaf.

Remarks ; Above sample is fit for Drinking Purpose W.r.t Physical & Bacteriological Analysis

Regd. Lab :  
Plot No. 1E, 1st & 2nd Floor, Shiv Vihar West  
Vikas Nagar,Uttam Nagar ,New Delhi-59 India  
Contact : +91 011 25634606 , 7011987165  
Mob : 7217618147  
E-Mail : demccdelhi@yahoo.co.in,director@delllabs.in

P.SL No. :  
Date

Whats App. :+91 7011987165,  
7217618147

Authorized Signatory

